

Purchasing Office
191 South East Street
Frederick, Maryland 21701
301-644-5116 phone
301-644-5213 fax



Stephen P. Starmer, C.P.M., Purchasing Manager
Kim Miskell, Assistant Purchasing Manager
Billie Laughland, Buyer Specialist
Bill Meekins, Buyer Specialist
Scott Bachtell, Buyer Specialist

December 13, 2013

CLARIFICATION #2

Bid 14C6, Unit Prices for Fuel System Cleaning, Maintenance and Fuel Oil Tank Replacement
Bid Opening Date: December 17, 2013 at 2:00 p.m., local time

This notice is being issued to provide the following clarifications to question asked:

Question: Can you please verify the size of the underground storage tank to be removed at Middletown Elementary and High Schools?

Answer: Middletown Elementary School has a 10,000 gallon underground steel tank to the right of the School, beyond the steps and facing the lower entrance.

Middletown High School has a 15,000 gallon underground steel tank in front of the school.

The above information is not a change in scope of the project and this clarification will not delay the bid opening

Thank you for your interest in bidding with FCPS.

Sincerely,

Bill Meekins

Bill Meekins CPPB, CPCP
Buyer Specialist

BM/kp

pc: Tony Ray, Construction Project Manager III,
Bid File