


Purchasing Office
191 South East St
Frederick, Maryland 21701
301-644-5212 phone
301-644-5213 fax



Stephen P. Starmer, C.P.M., CSBA,
Purchasing Manager
Kim Miskell, Assistant Purchasing Manager
Bill Meekins, CPPB, CSBO, CPCP,
Purchasing Agent
Billie Laughland, Purchasing Agent
Shane Ryberg, Purchasing Agent

June 6, 2018

ADDENDUM 2
RFP 18M12, Elevator Maintenance and Testing

DUE DATE: June 18, at 2:00 P.M.

This addendum is being issued to modify information contained in Addendum 1.

1. Delete number 13) and 14) from Addendum 1, and replace the question and answer with the following:
 - Q. Does the owner of the equipment own proprietary tools and equipment required to maintain and service the equipment? The Otis Gen II controllers at 650 Carroll Way require a proprietary code reader to read fault codes and modify parameters. Otis Elevator will not sell the service tool required to contractors. They will only sell the tool to the owner of the equipment. Should FCPS not own the service tool, will they be purchasing them?
 - A. Upon further evaluation and consideration of this issue, FCPS will purchase the necessary code reader to service the Otis Gen II units.

Sincerely,

Billie Laughland

Billie Laughland, Purchasing Agent
billie.laughland@fcps.org

BL/kl

cc: Randy Connatser, Project Manager IV, Maintenance and Operations Department
Erik McKay, Maintenance Area Supervisor
Travis Tracey, CMMS Support and Data Quality Specialist
Bid File