

Purchasing Office
191 South East Street
Frederick, Maryland 21701
301-644-5116 phone
301-644-5213 fax
billy.meekins@fcps.org



Kerrie Koopman CPPB, CPPO,
Purchasing Manager
**Kim Miskell, CSBO, Assistant Purchasing
Manager**
Bill Meekins CPPB, CPPO, CSBO, CPCP,
Purchasing Agent
Shane Ryberg, Purchasing Agent

ADDENDUM

April 16, 2020

ADDENDUM # 4

Bid 20C7, Catoctin High School Parking Improvements

DUE DATE: Tuesday, April 21, 2020, prior to 2:00 P.M. at <https://secure.procurenow.com/portal/fcps>

This addendum is being issued to provide additions, corrections, clarifications and answers to certain questions raised referencing the original proposal packages and any resultant contracts for the above bid.

1. Question: Will Fiberglass Light Poles be considered provided they are equal or better to the AASHTO LTS-5 Standards?
Answer: No, substitution request is rejected.
2. Question: Will Fluoropolymer based powder coat finishes be acceptable for fiberglass, which is an equal or better coating to the specifications for traditional materials?
Answer: No, substitution request is rejected.

Thank you for your interest in bidding with Frederick County Public Schools and we apologize for any inconvenience this may have caused.

Sincerely,

Kim Miskell

Kim Miskell, CSBO
Assistant Purchasing Manager

KM/ab

cc: Tom Mulligan, Project Manager III, Construction Management